



PPF 系列 壓力流量傳感器 操作說明書


PPF Series - Pressure & Flow Meter User Manual

繁 En

訂購稱呼代號 How to Order

機種仕樣 Model	流量大小 Flow rate	連接口徑 Port size	監控輸出 Monitor Output	開關輸出 Switch output	附件 Bracket	電纜接頭 Cable connector																																																																
PPF 系列 壓力流量傳感器 PPF Series - Pressure & Flow Meter User Manual	<table border="1"> <tr><th>型號</th><th>流量</th></tr> <tr><td>100</td><td>10L/min</td></tr> <tr><td>200</td><td>20L/min</td></tr> <tr><td>500</td><td>50L/min</td></tr> <tr><td>1000</td><td>100L/min</td></tr> <tr><td>2000</td><td>200L/min</td></tr> <tr><td>5000</td><td>500L/min</td></tr> <tr><td>10000</td><td>1000L/min</td></tr> </table>	型號	流量	100	10L/min	200	20L/min	500	50L/min	1000	100L/min	2000	200L/min	5000	500L/min	10000	1000L/min	<table border="1"> <tr><th>型號</th><th>口徑</th></tr> <tr><td>C04</td><td>Φ4</td></tr> <tr><td>C06</td><td>Φ6</td></tr> <tr><td>C08</td><td>Φ8</td></tr> <tr><td>PC4</td><td>Rc 1/2</td></tr> </table>	型號	口徑	C04	Φ4	C06	Φ6	C08	Φ8	PC4	Rc 1/2	<table border="1"> <tr><th>型號</th><th>口徑</th><th>PPF</th></tr> <tr><td>RS</td><td>RS485</td><td>100 200 500 1000 2000 5000 10000</td></tr> <tr><td>V</td><td>電壓型 DC1-5V</td><td></td></tr> <tr><td>V</td><td>電壓型 DC1-5V</td><td></td></tr> </table>	型號	口徑	PPF	RS	RS485	100 200 500 1000 2000 5000 10000	V	電壓型 DC1-5V		V	電壓型 DC1-5V		<table border="1"> <tr><th>型號</th><th>形式</th><th>規格</th></tr> <tr><td>N</td><td>NPN型</td><td>集電極/射極</td></tr> <tr><td>P</td><td>PNP型</td><td>集電極/射極</td></tr> </table>	型號	形式	規格	N	NPN型	集電極/射極	P	PNP型	集電極/射極	<table border="1"> <tr><th>型號</th><th>形式</th><th>規格</th></tr> <tr><td>B</td><td>流線型</td><td>扁托斯</td></tr> <tr><td>L</td><td>夾持式</td><td>扁托斯</td></tr> </table>	型號	形式	規格	B	流線型	扁托斯	L	夾持式	扁托斯	<table border="1"> <tr><th>型號</th><th>電纜</th></tr> <tr><td>N</td><td>無電纜</td></tr> <tr><td>S</td><td>直徑型 2m</td></tr> <tr><td>H</td><td>直角型 2m</td></tr> </table>	型號	電纜	N	無電纜	S	直徑型 2m	H	直角型 2m
型號	流量																																																																					
100	10L/min																																																																					
200	20L/min																																																																					
500	50L/min																																																																					
1000	100L/min																																																																					
2000	200L/min																																																																					
5000	500L/min																																																																					
10000	1000L/min																																																																					
型號	口徑																																																																					
C04	Φ4																																																																					
C06	Φ6																																																																					
C08	Φ8																																																																					
PC4	Rc 1/2																																																																					
型號	口徑	PPF																																																																				
RS	RS485	100 200 500 1000 2000 5000 10000																																																																				
V	電壓型 DC1-5V																																																																					
V	電壓型 DC1-5V																																																																					
型號	形式	規格																																																																				
N	NPN型	集電極/射極																																																																				
P	PNP型	集電極/射極																																																																				
型號	形式	規格																																																																				
B	流線型	扁托斯																																																																				
L	夾持式	扁托斯																																																																				
型號	電纜																																																																					
N	無電纜																																																																					
S	直徑型 2m																																																																					
H	直角型 2m																																																																					


輸出選擇 Output



確認開關訊號NPN或PNP型，並依需求選擇

輸出訊號	電壓型	DC1-5V
輸出阻抗	電壓型	50kΩ

PPF電纜線材規格表 Specification



RS485通信規格

PIN	線色	內容
01	藍	電源-(GND)
02	棕	RS485+
03	棕	電源+(24V)
04	白	CH1(開關輸出1: max50mA)
05	黑	CH2(開關輸出2: max50mA)
06	灰	RS485-

電壓輸出規格

PIN	線色	內容
01	藍	電源-(GND)
02	棕	流體電壓輸出: 1-5V 負荷阻抗50kΩ以上
03	棕	電源+(24V)
04	白	CH1(開關輸出1: max50mA)
05	黑	CH2(開關輸出2: max50mA)
06	灰	壓力電壓輸出: 1-5V 負荷阻抗50kΩ以上

* 電壓接頭也有直角型，直角型的接頭為向下引出 (OUT)
* 電纜接頭採旋轉式，若無旋轉時，則會造成接頭接觸不良

使用安全事項與警告

使用安全警告與注意事項分為「危險」、「警告」、「注意」。

危險：表示如果進行操作，有可能導致死亡或重傷的危險內容並且危險發生時的緊急性(需急救援)高的情況。
警告：表示如果進行錯誤操作，有可能導致死亡或重傷的危險內容。
注意：表示如果進行錯誤操作，有可能導致輕傷或財物損失的危險內容。

關於使用流體

危險


- 嚴禁用於易燃性氣體

注意

- 請使用不含氯、硫磺、酸等腐蝕成分的乾燥氣體，且不含灰塵及油霧的乾淨氣體。
- 使用壓力範圍：請參考規格書之額定範圍內使用，否則會影響感測器的使用壽命。
- 含大量冷凝水的壓縮空氣會造成本產品或其他驅動元件不良的原因。請接後冷卻器、空氣乾燥器、冷媒水收集器等對策。
- 由於空壓機產生的過多粉屑會附着在本產品內部，成為動作不良的原因。
- 各系列的耐壓性不同，選擇時請多加注意。
- 請遵守測定流量、使用壓力。(使用規範以上的壓力會造成產品損壞)
- 感測器的一次端使用開閉時，請使用禁油規格的開，否則可能因潤滑油飛濺造成感測器失靈或破壞。
- 使用容積器等液化氣體時，請務必氣化後使用，因為液化的氣體混入本產品可能導致產品故障。
- 流體中可能含有雜質，請將過濾器設置於前部。(建議空氣管路)

警告

- 不能作為商用儀表使用
- 不適用於計量法，因此不適用於商業交易。請僅為工業用測試用途使用。
- 除測用流體之外的流體由於不能保證其精度，因此請不要使用。
- 請先確認調壓閥調整後，再讓流體流動。(以免因加速感測壓力的限制，導致損壞)
- 感測器的一次端使用開閉時，請使用禁油規格的開，否則可能因潤滑油飛濺造成感測器失靈或破壞。
- 使用容積器等液化氣體時，請務必氣化後使用，因為液化的氣體混入本產品可能導致產品故障。
- 流體中可能含有雜質，請將過濾器設置於前部。(建議空氣管路)



關於佈線

危險

- 電壓電壓及輸出線使用規格電壓。(如施加規格以上之電壓，則可能造成本產品受損或觸電，最嚴重可能會導致火災)

警告

- 請勿負載短路。(本產品有加設過電保護，但無法保證所有錯誤配線，所以請多加注意配線)
- 請確認配線上的絕緣性。
- 請勿把電力線與動力線合為同一配線。(請採用不同配線以免包含開關的控制回路產生干擾而造成動作的原因)
- 請勿在插電中進行配線。(以免造成接地阻損壞或觸電危險)
- 設置本產品及配線時，請遠離強電流電線等雜訊源，而加載於電源線的突波請另外採取應對策，否則可能造成顯示或輸出異常。
- 在流量計動作過程中，請勿接觸電子或插座。(以免觸電、產生運作錯誤或損壞開關)
- 不穩定的電流有時超過額定電流，或導致本產品損壞，或導致本產品精度下降。

- 請停止控制裝置、機械裝置後，在切斷電源的狀態下進行檢修。如果安裝若過快進行有礙緊急危險發生時動作，這樣非常危險。請先使控制裝置、機械裝置暫時停止狀態進行通電試驗，並進行開關資料設定。操作前，操作申請將人頭、工具、裝置所帶的靜電充分放電後進行操作。活動部位使用類似機器人用線材的具有耐屈曲性的線材進行連接佈線。
- 切勿不關電源，因為可能導致本產品破裂或燒毀。
- 本產品之電線接頭含有防塵蓋之接頭，未使用本產品之接頭，請做好接頭之防護，以防止灰塵等不良因素導致其問題。
- 配線時，請確認配線的顏色及端子號碼。請確認配線會導致開關損壞、故障與配線錯誤的發生。因此，在配線前請確認說明書上的配線顏色及端子號碼後再進行配線，並請使用容量充足且波動小的DC電流。
- 本產品在感電後由於自身診斷需要耗時約四秒，這段時間內流量輸出開關不動作，通電後約四秒設置為無視訊號的程式設定。
- 本產品之RS-485規格，不含終端電阻。

注意

- 動作過程中如果發生異常，請立即切斷電源，停止使用本產品，並與銷售店聯繫。
- 本產品的流量讀數保持在額定流量範圍內。
- 設定輸出的設定值時，控制系統有可能會自動動作，因此請停止裝置運行後再變更輸出設定值。
- 請一年至少定期檢查一次本產品，確認本產品正常動作。
- 請不要拆卸本產品，否則可能會造成故障。
- 外殼材料為樹脂，去除污漬時請不要使用酒精、酒精、清潔劑等。
- 請在安裝前或感測器產生的電氣、與流量感測器相同的電氣上連接含流量感測器的其他元件時，為確認控制器的輸入裝置動作。如果使開關輸出線和電源線一併配線或切斷電源線一併，可能會在流量感測器的開關輸出迴路上產生逆向電流，造成流量感測器損壞。

關於安裝


警告

- 請注意流體的方向。(流動方向請依照本體所指示的前部方向)
- 安裝前請先將感測器清除安裝內的污物。
- 請勿搖動、拍打。(若施加過大的撞擊，有可能導致內部損壞)
- 在安裝時，請勿拉扯電線，以免拉力過大導致損壞。

注意

- 本產品LCD顯示器之流量，可能因為角度不同會有看不清楚的情況。
- 請使用適當的扭矩來調整流量計。
- 使用本產品，請在沒有震動的情況下，先通電用過氣，以確保產品零點校正正確。
- 使用差壓式流量計，請確保提供穩定的壓力源。
- PPF系列大流量計在工作壓力方面建議在5bar以上。若低於5bar則可量測的流量工作範圍會縮小。
- 本產品在感電後由於差壓特性，流體內含有壓力差導致氣流不能瞬間停滯，建議將氣排出口可以幫助恢復至零點。


















① 螢幕顯示、操作按鍵和功能



1 操作模式/一般模式

■ 累計流量顯示























<及時流量顯示畫面>



2 標準設定模式

■ 如何進入標準設定模式

<及時流量顯示畫面>



注：電壓切斷後再變壓時，解鎖或鎖鍵功能都會保持。

當鎖鍵功能啟動之後，所有的按鍵動作將不會有動作反應，除了解鎖功能。

當鎖鍵之後，如果按任何一個按鍵，螢幕將顯示“Loc”的字樣。

註1：此為RS485功能的流量計專用功能

How to operate/ Normal mode

Displaying the integrated flow

<instantaneous flow rate display>

Display unit selection
Press once

Real-time flow rate checking
Switch

Integrated flow rate (unit: L)
CO₂ discharge amount display
CO₂ unit = Kg

Press once (determination)
Press simultaneously for 2 sec.
Real-time flow rate checking

Integration or CO₂ reset
Integration is reset when the **ON** and **OFF** keys are held down for 2 sec.

Peak-holding function

<instantaneous flow rate display>

Press **ON** and **OFF** simultaneously

High-peak displayed
Low-peak value display

Press once
Reset peak-holding function, to real-time flow rate display.

Key lock function

• Key lock

<instantaneous flow rate display>

Press **ON** and **OFF** simultaneously for 1 sec.
Real-time flow rate display (lock)

• Unlock
<instantaneous flow rate display>

Press **ON** and **OFF** simultaneously for 3 sec.
Instantaneous flow rate display (unlock)

Note: Keys are unlocked when the controller is shipped. Lock keys if necessary. The key lock/unlock state is held even if power is turned OFF. While key lock, all the operations are not accepted excluding the key lock release operation. While key lock, if the key is operated, it becomes a "lock" display.

Standard setting mode

How to enter to Standard setting mode

<instantaneous flow rate display> Display unit selection 3 times

Press for 3 sec.

<Switch output> CH1
To switch output setting display
Press once (determination)

<Select output Function> ON
To forcible output setting display
Press once (determination)

<0 point adjustment> 8dJ
To 0 point adjustment setting display
Press once (determination)

<Display speed selection> d-SP
To display speed setting display
Press once (determination)

<Displayed color selection> CLor
To displayed color setting display
Press once (determination)

<CO₂ discharge amount setting> L02
To CO₂ discharge amount calculation setting display
Press once (determination)

<Sleep mode setting> CL05
To sleep mode setting display
Press once (determination)

<Unit switch setting> Uo it
To unit switch setting display
Press once (determination)

<Display fine turning setup page> F inE
To fine turning setting display
Press once (determination)

<ModBus RTU setting> Note1
485
To ModBus RTU setting
Press once (determination)

<Reset setting> rESE
To reset setting display
Press once (determination)

<Model number> R. n
To instantaneous flow rate display
Press once (determination)

Note1 : only for RS485 functionality

Data setting of switch output function

Press **ON** or **OFF** key to select flow rate unit.
Press **ON** key to set.

<Pressure/Flow switch output selection> CH1 FLO
Press once (determination)

<Switch output OFF> FLO
Press once (determination)

<Window operation 1> Window operation 2
FLO FLO

<Integrated pulse output> PLS FLO
Press once (determination) ON/OFF data setting

<Hysteresis operation 1> Hysteresis operation 2
FLO FLO

<Integrated output 2> Integrated output 1
FLO FLO

CH1 ON/OFF data setting

<Upper limit data setting> 200
Press once for lower limit setting.

<Lower limit data setting> 100
Press once (determination)

Value up Press **ON** key once to increase by one figure and press **ON** continuously to keep set figure increased.

Value down (vice versa) Press **OFF** key once to decrease by one figure and press **OFF** continuously to keep set figure decreased.

Real-time flow rate checking
Note: The switch mode is preset to the upper limit to start setting, after setting, press the M key to set the lower limit.

Switch action description

Mode	LCD display	Action description
Window operation 1	- n -	Switch output ON within the specified range
Window operation 2	- u -	Switch output ON outside the specified range
Hysteresis operation 1	- o -	Set a hysteresis range, when it reaches the specified flow rate or more, the switch output is OFF.
Hysteresis operation 2	- o -	Set a hysteresis range, when it reaches the specified flow rate or more, the switch output is ON. (Display shows 000 value and number input)
Integrated output 1	S - r	When reaches the specified flow rate or more, the switch output is ON.
Integrated output 2	S - L	When reaches the specified flow rate or more, the switch output is OFF.
Integrated pulse output	PLS	Set up an upper limit and trigger a pulse signal for 40ms when the count gets over it.
Switch output to OFF	- - - -	Switch to OFF

Select function output mode

<Select function output> 00
Press **ON** or **OFF** key to select pressure or flow select function output

<Being held down (CH1 & CH2 output OFF)> CH1 CH2
Press once (determination)

<Being held down (CH1 output ON)> CH1 CH2
Press once (determination)

<Being held down (CH2 output ON)> CH1 CH2
Press once (determination)

<Being held down (CH1 & CH2 output ON)> CH1 CH2
Press once (determination)

0 point adjustment mode- display setting

<0 point adjustment> R dJ
Press **ON** or **OFF** key to select pressure or flow adjustment mode

<Pressure/Flow 0 point setting selection> R dJ FLO
Press once (determination)

<Flow 0 point setting display> R dJ 10
Press once (determination)

<Adjust to 0 point> R dJ 0
Press once (determination)

<Pressure 0 point setting display> R dJ
Press once (determination)

To instantaneous flow rate display

Setting of display speed

<Display speed selection> d-SP
Press **ON** or **OFF** key to select pressure or flow display speed mode

<Pressure/Flow display speed selection> d-SP FLO
Press once (determination)

<Flow-speed setting display> d-SP 250
Press once (determination)

<Pressure-speed setting display> 250 d-SP
Press once (determination)

250msec (initial set) · 500msec · 1000msec

To instantaneous flow rate display

Setting of display color

<Color setting display> CLor
Press **ON** or **OFF** key to select response time. Press **ON** key to set.

Red when ON Red when OFF
Green when ON Green when OFF

Always RED Always Green

Press once (determination)
To instantaneous flow rate display

CO₂ discharge amount calculation setting

<CO₂ discharge amount setting> L02
Press **ON** or **OFF** to select CO₂ discharge amount setting

<Power input> Pow 020
Value up Value down (SET)

<discharge pressure> bAr 100
Press **ON** key once to increase by one figure and press it continuously to keep set figure increased. (vice versa)

<discharge flow rate> Flo 100
Value up Value down (SET)

<CO₂ conversion> L02 0000
Press once (determination)
To instantaneous flow rate display

Note1: Compressor's power input (kW)
Note2: Compressor's discharge pressure input (bar)
Note3: Compressor's flow rate input (L/min)
Note4: CO₂ conversion coefficient input (kg/CO₂/kwh)

Sleep mode setting

<Sleep mode setting> CL05
Press **ON** or **OFF** to select sleep mode setting

<Sleep mode-ON> CL05 on
Press **ON** or **OFF** to select sleep mode setting. Press **ON** key to set.

<Sleep mode-OFF> CL05 off

Note1: Press any key in power saving mode and the display resume lighting up.
Note2: The power saving mode will last for 1 minute each time.
Note3: The control functions remains intact in power saving mode.

ModBus RTU setting

<RS485 set> 485
Press **ON** or **OFF** to select RS-485 mode setting

Transmission Rate Configuration: 9600
Transmission Format Configuration: 8-N-1
Station Address: 1

Even Parity: 10 255
Data Biting: 8

Note 1: Transmission rate defaults to 9600
Note 2: Transmission format defaults to: n8L
Note 3: Station Address defaults to 1.

Note: This menu is available only for RS485 functionality as per the specification selection.

Unit switch setting

<Unit switch setting> Uo it
Press **ON** or **OFF** key to select pressure or flow unit switch setting

<Pressure/Flow unit setting selection> U n it FLO
Press once (determination)

<Unit: L/min> U n it bar
Press once (determination)

Note: Initial setting unit: L/min

<Unit: CFM> U n it kPa
Press once (determination)

<Unit: psi> U n it PrE
Press once (determination)

To instantaneous flow rate display

Display fine turning setup page

<Display fine turning setup page> F inE
Press **ON** or **OFF** key to display the advanced setup for pressure or flow

<Fine turning setup-OFF> F inE off
Press once (determination)

<Fine turning setup-ON> F inE on
Press once (determination)

<Pressure/Flow display fine turning setup page> F inE FLO
Press once (determination)

<Setup to fine tune the flow display> - 5.0 FLO
Value up Value down (SET)

<Setup to fine tune the pressure display> 0.7 PrE
Value up Value down (SET)

Note: The fine tuning mode comes with default value at 80%, the setup range spans from the negative to positive of its maximum value.

instantaneous flow rate display
Before fine tuning: 503.135
After fine tuning: 503.130

Before fine tuning: 503.135
After fine tuning: 5.10.135

Reset to the initial setting

<Reset is not executed> rESE off
Press **ON** or **OFF** to reset. Press **ON** to set to instantaneous flow rate display

<Reset is executed> rESE on

Mode number display

<Mode number> R. n
Press **ON** or **OFF** key to select pressure or flow unit switch setting

<Working fluid> <Switch output>
A: Air N: NPN output P: PNP output

Full scale flow rate
Main display section
Sub-display section

Pressure Flow mark

Press once (determination)
To instantaneous flow rate display

<instantaneous flow rate display> 503.135

Error code messages and troubleshooting

Overcurrent error

<CH1-Overcurrent error> 800 Er-1
-Load of flow switch output channel 1 goes over 125mA>

<CH1-Overcurrent error> Er-1 200
-Load of pressure switch output channel 1 goes over 125mA>

<CH2-Overcurrent error> 800 Er-2
-Load of flow switch output channel 2 goes over 125mA>

<CH2-Overcurrent error> Er-2 200
-Load of pressure switch output channel 2 goes over 125mA>

Readings reset error

<Flow reading reset error> 800 Er-3
-The instant flow reset goes over ±10%>

<Pressure reading reset error> Er-3 200
-The pressure reset goes over ±3%>

System error

<System error (memory, data access, system parameter anomalies)> Er-4 Er-4

Measurement error

<Pressure goes over the upper limit> H H H 200
-Please set input pressure in display range of the product >

<Instant flow goes over the upper limit> 800 H H H
-Please set the flow in display range of the product >

<Pressure goes below the lower limit> L L L 200
-Please set input pressure in display range of the product >

<Instant flow goes below the lower limit> 800 L L L
-Please set the flow in given direction >

ModBus RTU command description

Register Number	Parameter	Access	Description
0x0000	MODBUS Address	R/W	0-9600(1-13200)/2-38400(3-115200)
0x0001	Communication rate	R/W	N: 9600(1-1800)/2-38400(3-115200)
0x0002	Parity	R/W	Hand decimal places according to specifications
0x0003	Pressure	R	Hand decimal places according to specifications
0x0004	temperature	R	Reading value is 2.3. temperature: 23.0
0x0005	Flow	R	Hand decimal places according to specifications
0x0006-0x0008	Integrated flow rate	R	0x0006: XX XXXX 9999 0x0007: XX 9999 XXXX 0x0008: 99 XXXX XXXX
0x0009	CO ₂	R	kg
0x000A	integrated flow rate reset	W	execution
0x000B	decimal point/flow	R	(displacement) 0 to 1/ 1-0 / 2-0 01 / 3-0 001
0x000C	decimal point/press	R	0 to 0.001
0x000D	display mode	R/W	0: Flow&Temp/ 1: Integrated flow rate/ 2: CO ₂
0x000E	CH1 state	R	0: OFF/ 1: ON
0x000F	CH1 category	R/W	0: Pressure/ 1: Flow
0x0010	CH1 mode	R/W	0: ON/ 1: window/ 2: window/ 3: hysteresis/ 4: hysteresis/ 5: integrated/ 6: integrated/ 7: PLS (Pressure mode only goes to 8)
0x0011	CH1 upper limit	R/W	Automatically corresponds to the selected pressure or flow rate
0x0012	CH1 lower limit	R/W	Automatically corresponds to the selected pressure or flow rate (PLS)
0x0013	NPN/PNP	R	0: NPN/ 1: PNP
0x001D	CO ₂ set / power	R/W	Set the power unit of the air compressor to kW
0x001E	CO ₂ set / press	R/W	Set the measurement of the air compressor to bar
0x001F	CO ₂ set / flow	R/W	The flow in the flow rate of the air compressor specification.
0x0020	CO ₂ set / coefficient	R/W	CO ₂ carbon emission coefficient
0x0021	Flow 0 point range	W	Flow is display range
0x002C	Pressure 0 point connection	W	Pressure returns to zero/R: Read the zero value
0x0022	Flow display fine-tuning set	R/W	0: 0.5% 1: 1.0% 2: 2.0%
0x0024	Sleep mode setting	R/W	0: OFF/ 1: ON
0x0025	Flow range	R/W	0: CH1/ 1: CH2/ 2: PLS
0x0026	Pressure / unit	R/W	0: bar/ 1: kPa/ 2: psi
0x0027	Rated pressure range	R	Maximum range of pressure sensing (the actual value needs to be multiplied by the decimal point of the pressure)
0x0028	Rated flow range	R	The maximum range of flow sensing (the actual value needs to be multiplied by the decimal point of the flow rate)
0x0029	Setting of display speed	R/W	0: 250msec/ 1: 500msec/ 2: 1000msec/ 3: 2000msec/ 4: 3000msec
0x002A	Setting of display color	R/W	0: R-ON/ 1: G- ON/ 2: R-Only red/ 3: G-Only Green
0x002B	Reset to the initial setting	W	execution
0x002D	key lock function	R/W	0: OFF/ 1: ON
0x002E	version number	R	execution

Function code

R/W	Description
03	Read flow meter parameters
06	Write flow meter parameters

Error code

code	Description
03	The data content is wrong or out of range